



**Phase II Municipalities
IDEP Reporting
On behalf of:**

Burton
Davison Twp.
Flint Twp.
Genesee County
Mt. Morris
Vienna Twp.

Clio
Fenton
Flushing
Grand Blanc
Mt Morris Twp.

Davison
Fenton Twp.
Genesee Twp.
Linden
Swartz Creek

***November 1, 2017 – March 1, 2020
Reporting Period***

Prepared by:

***The Genesee County Drain Commissioner SWM
On behalf of Genesee County and contracted Communities***

This report summarizes activities completed for the period from November 1, 2017, to March 1, 2020, by the Genesee County Drain Commissioner's Office and the contracted Phase II Municipalities to meet the requirements of their National Pollutant Discharge Elimination System (NPDES) permit. This report is broken into six sections to coincide with the MI Waters website.

- PPP
- PEP
- **IDEP**
- General Permit Requirements

The Illicit Discharge Elimination Plan (IDEP) is a program to eliminate illicit discharges and connections, including the discharge of sanitary wastewater, to Municipal Separate Storm Sewer System (MS4). The County agent through a contract with the referenced communities conducts dry weather screening of all municipal separate storm sewer system (MS4) outfalls and point of discharges

Dry Weather testing is performed over the permit cycle. Once the 2008-2013 permit cycled ended, dry weather testing continued from 2014-current.

This section summarizes the IDEP activities including the ***illicit connections** identified during the 2017-2020 IDEP field investigations.

2017 2020 Outfalls – Dry Weather testing

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
7728757	C of Burton	Thread Creek Howe Rd Br 1357	High	7/30/2018
9615770	C of Clio	Pine Run Tributary	Medium	6/4/2018
9614530	C of Clio	Collins Drain 0025	Medium	6/4/2018
9614531	C of Clio	Collins Drain 0025	Medium	6/4/2018
9615772	C of Clio	Pine Run	Medium	6/4/2018
5623507	C of Fenton	Shiawassee River	Medium	6/4/2018
5623754	C of Fenton	Lake Fenton (Shiawassee)	Medium	6/4/2018
5636037	C of Fenton	Shiawassee River	Medium	6/5/2018
5636038	C of Fenton	Shiawassee River	Medium	6/5/2018
5636753	C of Fenton	Shiawassee River	High	6/5/2018
5626501	C of Fenton	Adams Drain	Medium	6/4/2018
5634255	C of Fenton	Egyptian Drain 0867	High	6/5/2018
5627253	C of Fenton	Lake Ponemah	High	6/5/2018
5626005	C of Fenton	Adams Drain 0124	Medium	6/4/2018
5626007	C of Fenton	Adams Drain 0124	Medium	6/4/2018
8527780	C of Flushing	Flint River	High	6/7/2018
8527781	C of Flushing	Flint River	High	6/7/2018
8534257	C of Flushing	Flint River	High	6/7/2018
*8526509	C of Flushing	Flint River	Medium	6/7/2018
8526501	C of Flushing	Flint River	Medium	6/5/2018
8526502	C of Flushing	Flint River	Medium	6/5/2018
8526511	C of Flushing	Flint River	Medium	6/5/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
8526513	C of Flushing	Flint River	Medium	6/5/2018
8526751	C of Flushing	Flint River	Medium	6/7/2018
8536010	C of Flushing	Messmore & Cronk	Medium	6/7/2018
8527256	C of Flushing	Flint River	Medium	6/7/2018
8527257	C of Flushing	Flint River Tributary	Medium	6/7/2018
8526752	C of Flushing	Flint River	High	6/7/2018
8526753	C of Flushing	Flint River	Medium	6/7/2018
8526754	C of Flushing	Flint River	Medium	6/7/2018
8525011	C of Flushing	Boman Drain 0062	High	6/5/2018
8526251	C of Flushing	Bowman Firman Branch	Medium	6/5/2018
8527504	C of Flushing	Cole Creek 0764	Medium	8/14/2018
8526507	C of Flushing	Flint River	Medium	6/7/2018
8527751	C of Flushing	Flint River	Medium	8/14/2018
5620522	C of Linden	Shiawassee River	Medium	6/6/2018
5620753	C of Linden	Shiawassee River	Medium	6/6/2018
5620251	C of Linden	Shiawassee River	High	6/6/2018
5620258	C of Linden	Shiawassee River	Medium	6/6/2018
5620755	C of Linden	Shiawassee River	Medium	6/6/2018
6502002	C of Swartz Cr	Swartz Creek West Branch 0122	High	6/6/2018
7632251	C of Swartz Cr	Swartz Creek West Br 0122	High	6/6/2018
6502264	C of Swartz Cr	Swartz Creek West Branch	High	6/6/2018
7718002	GC B&G	C of Flint- Flint River	High	7/26/2018
7718005	GC B&G11	C of Flint- Flint River	High	7/26/2018
7718001	GC B&G14	C of Flint- Flint River	High	7/26/2018
7718501	GC B&G15	C of Flint- Flint River	High	7/26/2018
7718502	GC B&G15	C of Flint- Flint River	High	7/26/2018
7718504	GC B&G15	C of Flint- Flint River	High	7/26/2018
7718503	GC B&G15/14	C of Flint- Flint River	High	7/26/2018
7734501	GC B&G2	C of Flint- Flint River	Medium	7/31/2018
7729504	GC B&G3	Schram & Ext 0320	High	7/30/2018
7718003	GC B&G7	C of Flint- Flint River	High	7/26/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
7718004	GC B&G7	C of Flint- Flint River	High	7/26/2018
8613104	GC School	Hughs Drain 0024	High	8/15/2018
8614251	GC School	MDOT Road Ditch	High	8/15/2018
6730301	GCDC 0006	Seaver Drain 0043	High	7/2/2018
7616752	GCDC 0009	Chapman Drain 0009	High	7/11/2018
8611256	GCDC 0013	Craven & Benson 0013	High	8/15/2018
7711760	GCDC 0017	Gilkey Creek 0017	High	7/26/2018
*8613106	GCDC 0024	Hughes Dr. 0024	High	8/15/2018
6612259	GCDC 0037	Sherwood 0162	High	6/25/2018
*7702009	GCDC 0039	Kearsley Creek	High	7/16/2018
7710012	GCDC 0048	Gilkey Creek 0017	High	7/26/2018
6704010	GCDC 0052	Thread Creek	High	6/26/2018
8623752	GCDC 0057	Lake Drain 0057	High	8/20/2018
8623751	GCDC 0057	Lake Drain 0057	High	8/20/2018
8704752	GCDC 0070	Saxton Drain 1210	*High	8/20/2018
7701766	GCDC 0073	Kearsley Creek	High	7/16/2018
7604755	GCDC 0075	Flint River	High	7/2/2018
6721253	GCDC 0078	Layman Drain 0385	High	7/2/2018
7532501	GCDC 0081	Davison Drain	High	7/2/2018
7728257	GCDC 0086	Thread Creek	High	7/30/2018
7625751	GCDC 0090	Gibson 0423	High	7/11/2018
7625755	GCDC 0090	Gibson 0423	High	7/11/2018
7810032	GCDC 0091	Black Creek 0704	High	7/31/2018
6621002	GCDC 0095	Howland Drain 0095	High	6/25/2018
8622747	GCDC 0109	Central Drain 0109	High	8/15/2018
8611762	GCDC 0110	Hannan 0110	High	8/15/2018
7701530	GCDC 0120	Kearsley Creek	High	7/16/2018
6613751	GCDC 0121	Brewer Drain #0121	High	6/25/2018
5635004	GCDC 0124	Adams Drain	High	6/13/2018
6722253	GCDC 0125	Layman Crosby Br 0710 via wetlands	High	7/2/2018
7804018	GCDC 0130	Brier Cr Drain 0130	High	7/31/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
5601001	GCDC 0132	Lake	High	6/14/2018
7625251	GCDC 0145	Gibson (City of Flint)	High	7/11/2018
6717753	GCDC 0150	Gibson 0423	High	6/26/2018
7815501	GCDC 0161	Long Lake 0614	High	7/31/2018
7702007	GCDC 0173	Kearsley Creek	High	7/16/2018
7806751	GCDC 0174	Cochran Drain 0174	High	7/31/2018
7731007	GCDC 0176	Gibson Drain 0145	High	7/30/2018
*8623749	GCDC 0181	Lake Drain 0057	High	8/20/2018
*7632415	GCDC 0189	Swartz Cr West Br of 0122	High	7/16/2018
7618501	GCDC 0190	Messmore & Cronk 0464	High	7/11/2018
8523752	GCDC 0195	Bowman Firman Br 0195	High	8/14/18
7816252	GCDC 0197	Long Lake 0614	High	8/6/2018
7816264	GCDC 0197	Long Lake 0614	High	8/6/2018
6602755	GCDC 0212	Call Ext 0767	High	6/25/2018
8512251	GCDC 0227	Armstrong Creek	High	8/14/2018
8527260	GCDC 0233	Flint River	High	8/14/2018
7628556	GCDC 0235	Swartz Creek West Br 0122	High	7/12/2018
6623001	GCDC 0242	Swartz Creek	High	6/25/2018
5602001	GCDC 0257	Dawn Drain 0257	High	6/14/2018
8705751	GCDC 0295	Saxton Drain 1210	*High	8/20/2018
7829755	GCDC 0300	Lobban Drain 0300	High	8/13/2018
8523753	GCDC 0303	GCDC 0195	High	8/14/18
6708508	GCDC 0313	Gibson Reid Road Branch	High	6/26/2018
8610751	GCDC 0315	Lake 0057	High	8/15/2018
8522251	GCDC 0316	Flint River	High	8/14/2018
7822501	GCDC 0317	Montague Drain 0317	High	8/13/2018
7729502	GCDC 0320	Schram & Ext 0320	High	7/30/2018
7635751	GCDC 0324	Call Ext 0767	High	7/16/2018
8634501	GCDC 0334	Hartshorn & Ext 0458	High	8/20/2018
7728755	GCDC 0337	Thread Creek	High	7/30/2018
7722003	GCDC 0344	Robinson & Curtis 0344	High	7/26/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
7722251	GCDC 0344	Robinson & Curtis 0344	High	7/26/2018
6502351	GCDC 0346	West Br Swartz Creek	High	6/13/2018
7625758	GCDC 0348	Gibson 0423	High	7/12/2018
8613248	GCDC 0349	Hughes Dr. 0024	High	8/15/2018
8522507	GCDC 0353	Flint River	High	8/14/2018
8629773	GCDC 0358	Hartshorn & Ext 0458	High	8/20/2018
7818002	GCDC 0368	Phillips 0080	High	8/13/2018
6502292	GCDC 0371	West Br Swartz Creek	High	6/13/2018
*7733258	GCDC 0375	Thread Creek	High	7/30/2018
7733254	GCDC 0375	Thread Creek	High	7/30/2018
8612751	GCDC 0378	...	High	8/15/2018
*7622753	GCDC 0398	Swartz Creek	High	7/11/2018
6712256	GCDC 0412	Thread Creek	High	6/26/2018
7819005	GCDC 0414	Phillips 0080	High	8/13/2018
8614504	GCDC 0420	Daily Drain 0420	High	8/15/2018
6705520	GCDC 0423	Gibson 0423	High	6/26/2018
6708021	GCDC 0423	Gibson 0423	High	6/26/2018
*7733752	GCDC 0434	Thread Creek	High	7/31/2018
8634502	GCDC 0435	Hartshorn & Ext 0458	High	8/20/2018
7830251	GCDC 0438	Phillips East Branch 0319	High	8/13/2018
6707501	GCDC 0444	Sherwood Drain	High	6/26/2018
7627251	GCDC 0445	Swartz Creek	High	7/12/2018
5622751	GCDC 0455	Lake Ponemah	High	6/13/2018
*8614503	GCDC 0462	Lake 0057	High	8/15/2018
7536752	GCDC 0482	West Br Swartz Creek	High	7/2/2018
6618252	GCDC 0503	Lum & Extension Br #2	High	6/25/2018
5616002	GCDC 0508	Loon Lake-Shiawassee	High	6/13/2018
7731538	GCDC 0523	Gibson Drain 0145	High	7/30/2018
8515754	GCDC 0538	GCDC 0538 to Flint River	High	8/14/2018
7805006	GCDC 0540	Brier Creek 0130	Medium	2018
8629774	GCDC 0549	Hartshorn & Ext 0458	High	8/20/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
8634503	GCDC 0581	Hartshorn 0458	High	8/20/2018
7635002	GCDC 0595	Call Ext 0767	High	7/16/2018
7816271	GCDC 0614	Long Lake 0614	High	8/6/2018
7701257	GCDC 0620	Brier Creek Drain 0130	High	7/16/2018
7809303	GCDC 0631	Harvey Drain 0631	High	7/31/2018
8621751	GCDC 0634	Stadler Drain 0113	High	8/15/2018
6611505	GCDC 0645	Swartz Creek	High	6/25/2018
6708012	GCDC 0655	Gibson 0423	High	6/26/2018
7809002	GCDC 0659	Black Creek 0704	High	7/31/2018
5525752	GCDC 0672	Hogan 0672	High	6/14/2018
6502294	GCDC 0675	West Br Swartz Creek	High	6/13/2018
6735259	GCDC 0681	Groat 0681	High	7/2/2018
6721757	GCDC 0702	Layman Pierson Br of 0702	High	7/2/2018
6722753	GCDC 0710	Layman Crosby Br 0710	High	7/2/2018
7628555	GCDC 0713	Swartz Creek West Br 0122	High	7/12/2018
7810257	GCDC 0726	Black Creek 0704	High	7/31/2018
7627751	GCDC 0769	Call Ext. Drain	High	7/12/2018
7627752	GCDC 0769	Call Ext. Drain	High	7/12/2018
7631252	GCDC 0795	Swartz Cr West Br of 0122	High	7/12/2018
8622749	GCDC 0820	Central Drain 0109	High	8/15/2018
6505006	GCDC 0848	Davison Drain 0081	High	6/13/2018
*7524001	GCDC 0861	Cole Creek 0764	High	7/2/2018
6608326	GCDC 0866	Bloss 0167	High	6/25/2018
5634251	GCDC 0867	Egyptian 0867	High	6/13/2018
5634270	GCDC 0867	Egyptian Drain	High	6/13/2018
5627003	GCDC 0867	Egyptian Drain	High	6/13/2018
6710522	GCDC 0899	Thread Cr	High	6/26/2018
8633751	GCDC 0927	Hartshorn & Ext 0458	High	8/20/2018
5621751	GCDC 0933	Ponemah Lake	High	6/5/2018
6717754	GCDC 0937	Gibson 0423	High	6/26/2018
6610751	GCDC 0943	Swartz Creek	High	6/25/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
5525001	GCDC 0969	Hogan drain 0969	High	6/14/2018
8613105	GCDC 0975	Hughes Dr. 0024	High	8/15/2018
8610752	GCDC 1012	Lake 0057	High	8/15/2018
6722751	GCDC 1020	Layman Crosby Br 0710	High	7/2/2018
7619002	GCDC 1073	Messmore & Cronk 0464	High	7/11/2018
7816270	GCDC 1078	Long Lake 0614	High	8/6/2018
7536505	GCDC 1079	Swartz Creek West Branch of	High	7/2/2018
7712505	GCDC 1139	Gilkey Creek 0017	High	7/26/2018
8613247	GCDC 1159	Hughes Dr. 0024	High	8/15/2018
6501501	GCDC 1160	Spillane & Branches Drain	High	6/13/2018
6601255	GCDC 1233	Sherwood Dr. 0162	High	6/14/2018
7731524	GCDC 1236	Sherwood 0423	High	7/30/2018
*6601757	GCDC 1236	Sherwood 0162	High	6/14/2018
7632416	GCDC 1270	Swartz Cr West Br of 0122	High	7/16/2018
7733259	GCDC 1318	Thread Creek	High	7/30/2018
7727758	GCDC 1319	Thread Cr Pierson Br 1319	High	7/30/2018
7632220	GCDC 1321	Swartz Creek West Br 0122	High	7/16/2018
7727504	GCDC 1357	Thread Creek Howe Br 1357	High	7/30/2018
*6611253	GCDC 1368	Call Ext 0767	High	6/25/2018
7830109	GCDC 1370	Phillips East Branch 0319	High	8/13/2018
7711509	GCDC 1379	Gilkey Creek 0017	High	7/26/2018
7622752	GCDC 1396	Swartz Creek	High	7/11/2018
7622751	GCDC 1396	Swartz Creek	High	7/11/2018
7821001	GCDC 1405	Kearsley Creek	Low	8/13/2018
7618502	GCDC 1409	Messmore & Cronk 0464	High	7/11/2018
5614501	GCDC 1411	Shiawassee River	High	6/14/2018
5614507	GCDC 1411	Shiawassee River	High	6/14/2018
*7628752	GCDC 1413	Swartz Creek	High	7/12/18
8522508	GCDC 1414	GCDC 1414 to Flint River	High	8/14/2018
7726253	GCDC 1417	Gilkey Creek 0017	High	7/30/2018
7628753	GCDC 1423	Swartz Creek	High	7/12/2018

Outfall ID	Owner	Receiving Waterbody	Priority	Date Investigated
6704006	GCDC 1430	Thread Creek	High	6/25/2018
7620751	GCDC 1434	Ryant Drain 0509	High	7/11/2018
7710754	GCDC 1494	Gilkey Creek 0017	High	7/26/2018
7627001	GCDC 1497	Swartz Creek	High	7/12/2018
6717253	GCDC 1512	Gibson Drain	High	6/26/2018
7723760	GCDC 1513	Gilkey Cr Atherton Br 1513	High	7/26/2018
7710763	GCDC 1514	Gilkey Creek 0017	High	7/26/2018
7710775	GCDC 1514	Gilkey Creek 0017	High	7/26/2018
5617513	GCDC 1521	Shiawassee Spring Meadows Br	High	6/13/2018
7828268	GCDC 1523	Kearsley Creek via wetlands	High	8/13/2018
5612001	GCDC 1525	EDEN GARDENS	High	6/14/2018
7736786	GCDC 1531	Gilkey Creek 0017	High	7/31/2018
8630758	GCDC 1551	Root Drain 0185	High	8/20/2018
7816752	GCDC 1567	Long Lake 0614	High	8/6/2018
7804016	GCDC 1658	Brier Cr Drain 0130	High	7/31/2018
7806265	GCRC	Brier Creek Drain 0130	Medium	2018
7806266	GCRC	Brier Creek Drain 0130	Medium	2018
7805001	GCRC	Brier Creek Drain 0130	Medium	2018
7806252	GCRC	Brier Creek Drain 0130	High	2018
7806003	GCRC	Brier Drain 0130	Medium	2018
6610751	GCRC	Swartz Creek	Medium	6/25/2018
9629004	Vienna Township	Brent Run	None	8/14/2018

***Dry weather testing that resulted in an illicit discharge and reported to GCDC-SWM**

Dry weather testing between October 2019 and March 2020 will be reported on in next reporting cycle.

Follow up from Incident Reports from Tetra Tech
Or illicit discharges reported from public

Sample Location	Background & Follow-up Inspection	Results & Comments
ID #6716252 340 Reid Rd City of Grand Blanc Sec-16	7/5/16: During dry weather flow investigation, Tetra Tech observed flow from a 36" pipe flowing southwest. Tetra Tech conducted sampling and found a high level of E. Coli. GCDC-SWM identified the source and working with City of Grand Blanc to eliminate the connection. Samples two times and results show below action level.	CLOSED
ID #7810046 Main St. Crossing Black Creek City of Davison Sec-10	On 7/5/16, Tetra Tech sampled outfall #7810046. City of Davison 18" PVC pipe located on south wall of the culvert crossing Black creek at Main street. Tetra Tech sampling results show elevated levels of E. coli and ammonia from the 18" PVC pipe. City of Davison identified the source and working with the Fire Dept. to eliminate the source. On 7-16-19 Fire dept. rerouted to Sanitary Sewer.	CLOSED
3100 Genesee Rd Genesee Twp. Sec-35	On 6-6-17, GCDC-WWS called about smell and sign of gasoline at driveway of 3100 Genesee road. There was a remediation site across street on west side. GCDC-SWM conducted a follow-up inspection.	CLOSED
ID #8527862 Flushing Twp. South end of S. McKinley Rd	On 9-6-17: Tetra Tech Sampled dry weather flow from 24" RCP discharging into Flint River. Lab results showed high level of E. Coli. Illicit connection eliminated.	CLOSED.
ID #5620519 Fenton Twp. Sec-20 West of N. Bridge Street	On 9-7-17: Tetra Tech Sampled dry weather flow from 24" RCP discharging into Shiawassee River. Lab results showed high level of E. Coli and surfactant. GCDC-SWM working to identify the source of illicit connection.	ON-GOING
15173 Restwood Dr. Linden, MI	On 11/23/17, pumped out contaminated water from cleanup operations of house fire into Byram Lake. Contained and cleaned.	CLOSED
2140 Painted Post Dr. Flushing, MI 48433	Conducted site inspection no evidence of for cleanup. Talked to property owner: No dumping into D/W in the future.	CLOSED
4467 Radcliffe St Flint	60" pipe periodic dumping soapy water into West Branch of Swartz Creek during Spring. Write a letter to all residents in the Drainage District not to discharge waste water into storm sewer.	CLOSED
100 Vienna Street Clio, MI	Cleaning Company spill floor cleaner. FD responded and flushed contaminants from the sign. Conducted a site inspection and did not observe any evidence.	CLOSED.

719 S State Street Davison,	Commercial site dumped grease into storm sewer. City of Davison cleaned the storm sewer system and wrote a notice of violation of City's storm sewer ordinance.	CLOSED
ID #8526509 4014 Dutch Mill Drive Flushing Twp.	In 2018, Tetra Tech sampled this outfall And found elevated levels of E. coli. GCDC conducted a follow-up site inspections. A source could not be identified.	ON-GOING
ID#6601757 NW corner of Fenton & Hill	On 6-14-18: Tetra Tech Sampled dry weather flow 15" tile discharging into the Sherwood Drain. Lab results showed E. Coli of 1553 > 1000 action level and discharge from the outfall looks colored and smell rotten food. GCDC conducted follow-up site inspection.	ON-GOING
ID#6611253 Taylor Drive	On 6/25/18: Tetra Tech Sampled dry weather flow 30" tile discharging into the Call Drain. Lab results showed high level of NH3= 8. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID#7524001 South side of Corunna	On 7-2-18: Tetra Tech Sampled dry weather flow from 12" tile discharging into Cole Creek Drain. Lab results showed high surfactant 0.94 but E. Coli was only 270. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID #7702009 Formar Nature Reserve City of Burton	On 7-16-18: Tetra Tech Sampled dry weather flow 42" tile discharging into Kearsley Creek. Lab results showed E. Coli of 2419 > 1000 and marginal surfactant. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID#7632415 5387 Miller Rd Flint Twp.	On 7-16-18: Tetra Tech Sampled dry weather flow discharging into Swartz Creek. Lab results showed marginal E. Coli & surfactant.of 0.43. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID#7622753 3129 Miller Rd Flint Twp.	On 7-11-18: Tetra Tech Sampled dry weather flow discharging into Swartz Creek. Lab results showed E. Coli= 2420 and surfactant= 1.8. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID #7733258 4050 Center Rd City of Burton	In 2018, Tetra Tech sampled this outfall. Sampling results did not show trace of E. Coli and surfactants. Ammonia found below action level. Outfall smells strongly of rotting food. Working with the adjacent business owners to eliminate the source. Continue to monitor.	ON-GOING

ID # 7733752 4303 Center Road City of Burton	On 7-31-18: Tetra Tech Sampled dry weather flow 30" tile discharging into Thread Creek. Lab results showed E. Coli above action level. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID # 7628752 4225 Miller Road Flint Twp.	On 7-12-18: Tetra Tech Sampled dry weather flow discharging into Swartz Creek. Lab results showed E. Coli above action level. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified	ON-GOING
ID #8623749 5100 Clio Road Mt. Morris Twp.	In 2018, Tetra Tech sampled this outfall And exceed threshold levels of E. coli. GCDC conducted a follow-up sampling, issue eliminated.	CLOSED
ID #8613106 6399 Central Garden Dr. Mt. Morris Twp.	In 2018, Tetra Tech sampled this outfall And found elevated levels of E. coli. GCDC conducted a follow-up site inspections and sampling analysis a source could not be identified.	ON-GOING
ID #8614503 6095 Ballard Dr. Mt. Morris Twp.	In 2018, Tetra Tech sampled this outfall And found elevated levels of E. coli, surfactants, and ammonia during dry weather flow. GCDC conducted several site inspections and sampling analysis a source could not be identified.	ON-GOING
104 W. Caroline St Fenton Twp. Sec-26	Waste water from hood cleaning inside the bakery discharges into parking lot storm sewer. Wrote a letter to owner not to discharge waste water from hood cleaning into storm sewer.	CLOSED
6247 W. Vienna Rd Vienna Twp.	Home owner used heating oil to kill dead tree roots. Homeowner cleaned residual home heating oil.	CLOSED
10195 Hegel Road Village of Goodrich	Oil residue from an auto repair shop flowing into county drain. Wrote a letter to the business owner to capture and contain oil residual at the site.	CLOSED
Fire Station #1 5447 Bicentennial Dr. Mt. Morris Twp.	Conduct a joint inspection with the Mt. Morris Twp. to confirm how the floor drain is connected. Confirmed floor drain is connected to sanitary Sewer.	CLOSED
Fire Station #2 4096 N. Saginaw St Mt. Morris Twp.	Conduct a joint inspection with the Mt. Morris Twp. to confirm how the floor drain is connected. GCDC was not able to confirm the floor drain is connected to sanitary Sewer as the sanitary main was locked. Will return & coordinate with WWS.	ON-GOING
Fire Station #3 1027 Louis Ave Mt. Morris Twp.	Conduct a joint inspection with the Mt. Morris Twp. to confirm how the floor drain is connected. GCDC was not able to confirm the floor drain is connected to sanitary Sewer	ON-GOING

Kroger City of Davison	Trash compactor leaking at the Kroger location. Waste Management inspected the trash compactor and found door seal is bad. WM replaced the door seal.	CLOSED
7377 & 7381 Haviland Beach Dr. Argentine Twp. Sec-36	7390 Haviland beach Drive complained about algae bloom at the lake. GCDC-SWM conducted a storm video and a sampling analysis to identify the source. Our investigations showed no illicit discharge at the lake.	CLOSED
City Auto Mall 12587 N. Saginaw Rd Vienna Twp.	Cleaning car in the parking lot. Inspected the site and found that waste water from car cleaning in the parking lot going to storm. Contacted GCDC-WWS and the owner about IPP permit. Owner is working with GCDC-WSS about IPP permit issue.	ON-GOING
8209 Linden Rd MT. Morris Twp. Sec-5	Complained about pipe from septic tank leaking. GCHD investigated the site the problem was corrected.	FILE CLOSED
5486 Richfield Road Genesee Twp.	Dumped residue of hydroseeding mulch into a catch basin of a county drain. Owner jet and vac the catch basin and corrected the problem.	FILE CLOSED.
Saganos Restaurant Flint Twp.	Anonymous caller called and complained that restaurant owner dumped cooking oil/grease into storm catch basin. Inspected the site and observed no sign of grease/oil	FILE CLOSED
4047 Market Place Flint Twp. Sec-28	Oil spilled from a truck at this address. Fire dept. notified Hazmat. Hazmat hired Young's Environmental for cleanup.	FILE CLOSED
900 Tacoma Ct. 51-15-551-019 Vienna Twp.	GCDC received a complaint that 4" black pipe discharging brown water in the backyard. Inspected the site and did not observe brown water.	FILE CLOSED
6256 Hidden Forest Gaines Twp. Sec-10	Oil tank leaked within the property. MDEQ was involved in cleanup works.	FILE CLOSED
619 N Genesee Rd City of Davison	Sanitary lead is backed up into sump pump crock. Sewer cleaner company clear the block. Sump pump discharge line disconnected. Owner will work to separate sump lead from SS lead.	ON-GOING
4396 Underhill Dr Genesee Sect 26	UST leaked during removal within the property. Cleanup was done. Only effected soils. Did not get into surface water	FILE CLOSED
1149 W. Klein Street Mt Morris Twp	Empty Elementary School sump failed. Pumping Clean water to grass area to access sump well. Received call from PEAS	FILE CLOSED